



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

James Eberts
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

8/24/2021

Phone: (856) 205-1077
Fax: (856) 205-0413

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 8/6/2021. The results are tabulated on the attached data pages for the following client designated project:

Project ID: NJ DOE
Pineland Learning Center

The reference number for these samples is EMSL Order #012109037. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012109037
 CustomerID: EPIC62
 CustomerPO: NJ-DOE
 ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 8/6/2021 09:00 AM

Project: **Pineland Learning Center**

Analytical Results

Client Sample Description Pine-FB
Field Blank **Collected:** 8/4/2021 6:01:00 AM **Lab ID:** 012109037-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:11

Client Sample Description Pine-IM-KITCH
Ice Machine Kitchen **Collected:** 8/4/2021 6:02:00 AM **Lab ID:** 012109037-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:18

Client Sample Description Pine-KC-KITCH
Sink - Kitchen by Freezers **Collected:** 8/4/2021 6:03:00 AM **Lab ID:** 012109037-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:19

Client Sample Description Pine-SO-Bistro
Sink in Bistro **Collected:** 8/4/2021 6:05:00 AM **Lab ID:** 012109037-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:22

Client Sample Description Pine-NR-NRRR
Sink Nurses Office Rr **Collected:** 8/4/2021 6:09:00 AM **Lab ID:** 012109037-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:24

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012109037
 CustomerID: EPIC62
 CustomerPO: NJ-DOE
 ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 8/6/2021 09:00 AM

Project: **Pineland Learning Center**

Analytical Results

Client Sample Description Pine-SO-RM120
Break Rm Sink
Collected: 8/4/2021 6:11:00 AM
Lab ID: 012109037-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:27

Client Sample Description Pine-BF-Hall1
Bottle Filler Hall by Break Rm
Collected: 8/4/2021 6:13:00 AM
Lab ID: 012109037-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:32

Client Sample Description Pine-SO-Lifesk
Sink Life Skills
Collected: 8/4/2021 6:14:00 AM
Lab ID: 012109037-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.66	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:36

Client Sample Description Pine-SO-Hall2
Sink Hall by Rm 209
Collected: 8/4/2021 6:17:00 AM
Lab ID: 012109037-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:39

Client Sample Description Pine-WC-Gym
Water Cooler Gym
Collected: 8/4/2021 6:21:00 AM
Lab ID: 012109037-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/19/2021 VD	8/20/2021 VD 02:41



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012109037
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results